

LISTA POMPE

LISTA POMPE PT 3

Nr. Crt.	Pompa	Tip	Caracteristici				Obs.
			Nr. buc.	Debit (m ³ /h)	H (mca)	Putere (Kw)	
1	Electropompa circuit incalzire Zona, IL 80/220 - 11/5	WILO	2	250	11	4	Funct/rezerva
2	Electropompa circulatie apa cazan IPL 100/145 - 1,5/4	WILO	4	100	4	1,5	Funct/rezerva
3	Electropompa circulatie schimbator	WILO	3	58	16	4	Funct/rezerva
4	Electropompa modul expansiune	WILO	2	1,7	35	0,55	Funct/rezerva
5	Electropompa adaos	Cerna 80	1	20	35	5,5	Funct.

LISTA POMPE PT 5

Nr. Crt.	Pompa	Tip	Caracteristici				Obs.
			Nr. buc.	Debit (m ³ /h?)	H (mca)	Putere (Kw)	
1	Electropompa circulatie schimbator	WILO	3	116	25	11	Funct/rezerva
2	Electropompa modul expansiune	WILO	2	3,4	35	0,75	Funct/rezerva
3	Electropompa adaos	Cerna 80	1	15	30	3,5	Funct
4	Electropompa circuit incalzire Zona, IL 80/220 - 11/5	WILO	2	250	11	4	Funct/rezerva
5	Electropompa circulatie apa cazan IPL 100/145 - 1,5/4	WILO	4	100	4	1,5	Funct/rezerva

LISTA POMPE PT 14

Nr. Crt.	Pompa	Tip	Caracteristici				Obs.
			Nr. buc.	Debit (m ³ /h?)	H (mca)	Putere (Kw)	
1	Electropompa circulatie schimbator	WILO	3	132	23	15	Funct/rezerva
2	Electropompa modul expansiune	WILO	2	3,8	35	0,75	Funct/rezerva
3	Electropompa adaos	Cerna 50	2	10	30	2,2	Funct/rezerva
4	Electropompa adaos	Cerna 60	1	20	35	5,5	Funct.

LISTA POMPE PT 20

Nr. Crt.	Pompa	Tip	Caracteristici				Obs.
			Nr. buc.	Debit (m ³ /h?)	H (mca)	Putere (Kw)	
1	Electropompa circulatie schimbator	WILO	3	21	12	1,5	Funct/rezerva
2	Electropompa modul expansiune	WILO	2	0,5	35	0,55	Funct/rezerva

PRESEDINTE DE SEDINTA
CONSILIER,

Marian Dragos PETCU

